

SECTION III

MODELING

SECTION III - TABLE of CONTENTS

3. MODELING..... III-1

3.1 Laboratory..... III-1

3.1.1 Large Laboratory..... III-1

3.1.2 Small Laboratory..... III-3

3.2 Hood III-3

3.3 Laboratory configurations III-6

3.3.1 Hood position III-6

3.3.3 Heating, Ventilating, and Air Conditioning III-40

3.3.4 Scientist in front of the hood III-41

3.3.5 Simulations performed III-41

3.4 Grid selection..... III-57

3.5 Assumptions III-63

3. MODELING

This section describes the primary features of the laboratories, the laboratory hood, and configuration variations as modeled in this project. As well as this general information, other specific variations are detailed (for example, the presence of a scientist in front of the laboratory hood). In particular, one of the key variations is associated with the diffuser type and position.

A summary of the different configurations is provided here with a full database of the simulations, their configuration changes, and summary results given in the appendix.

3.1 Laboratory

Two basic laboratory modules are defined in order to investigate the effect of air flow within the laboratory on the containment efficiency of the hood. The two sizes chosen are representative of large (33 ft x 22 ft) and small (22 ft x 11 ft) laboratories.

3.1.1 Large Laboratory

The large laboratory (figure 3.01) occupies a floor area of 33 ft (10.06 m) by 22 ft (6.70 m). The ceiling height is 10 ft (3.05 m). There are three doors and two windows in the walls of the laboratory. Working space is provided within the laboratory in the form of three benches; one along each of the longer walls and one down the center of the room. A number of tall cupboards and five desks are also provided in the laboratory area.

For all but the displacement ventilation simulations, air is introduced through ceiling mounted diffusers. All the air exits the laboratory through the general laboratory exhaust and/or the fume hood(s). In line with common practice more air is exhausted than supplied. As a result, for most simulations, make up air is allowed to enter through a crack under the main door placed in the shorter wall.




Figure 3.01 Layout of large laboratory

The majority of simulations have a total heat load of 8 W/ft^2 , a lower or higher heat load is applied in selected simulations to determine sensitivity. Included in this is lighting (2.3 W/ft^2) in the form of fluorescent tubes suspended from, or recessed into, the ceiling. The remaining heat load is distributed around the laboratory. A source of heat, distributed over an appropriate volume, is placed upon each desk to represent equipment such as computers. In some simulations a scientist is modeled working in front of the fume hood, with their chest either 4" or 6" away from the sash of the hood, and their arms extending through the sash opening.

3.1.2 Small Laboratory

The small laboratory (figure 3.02) has dimensions 22 ft (6.7 m) by 11 ft (3.35 m) with a ceiling height of 10 ft (3.05 m). There are two doors and one window in this laboratory. The conceptual layout and heat gains for this laboratory are basically the same as for the larger laboratory. Of course, due to more limited space there is no central bench and only one desk.

Air is introduced at the ceiling level and is removed through the laboratory hood. In many of the simulations the imbalance is such that a make - up air grille is required, normally in addition to the crack under the door. This make - up air grille is placed above the main door placed in the short wall.

3.2 Hood

The laboratory hood is modeled by describing the physical surfaces and objects with any associated flow and heat transfer (figure 3.03). The following describes the representation used for the simulations undertaken in this project.

It is well known that the design of the laboratory hood can significantly affect the containment performance, hence for this research a generic 4 foot (total width, 1.22 m) hood is selected. Since this project is not intended to address the effect of actual laboratory hood design or the dynamics of the associated hood ventilation system, the model simulates the flow from the laboratory only as far as the slots in the rear baffle. The flow rate through each of these slots and the slot sizes and their positions are prescribed on the basis of previously determined experimental data (Memarzadeh, 1989). This approach should ensure that the performance in practice is at least as good as that predicted, since an aerodynamically designed hood would be expected to perform as well as or better than the generic hood modeled here.






Figure 3.02 Layout of small laboratory.



Front view of fume hood



Back view of fume hood

Figure 3.03 General layout of fume hood models

The sash is assumed to be at its maximum opening position (30 in, 0.76 m) for the majority of simulations, however, some simulations are conducted with the sash at 25% opening. The width of the open region of the hood is 3 ft 2 in (0.96 m). The total flow - rate through the hood for the majority of the simulations is set so that the average face velocity is 100 fpm (0.507 m/s). Some of the simulations are undertaken with an average face velocity of 50 fpm (0.254 m/s), thus allowing comparison of the two standards.

For some simulations, a bulkhead was included above the hood (figure 3.04) so the cabinet of the hood extends all the way to the ceiling.

In practice, the hood leakage rate is directly related to the rate of the contamination source inside the hood, representing an infinite number of conditions. In order to determine the relative leakage rate of the hood in different laboratory configurations, the sash opening is filled with contamination to represent a worst case scenario. Thus any leakage from the hood can be observed and quantified. The leakage predicted by the simulation can be considered as a factor that can be applied to a known concentration inside the hood. Thus the leakage from within the laboratory hood through the sash opening into the working zone, and, from the working zone into the laboratory can be predicted for any given source. Diagrams showing concentration distributions can be similarly scaled by multiplying the predicted concentrations by the actual concentrations in the laboratory hood.

3.3 Laboratory Configurations


To investigate a wide range of parameters, the basic models described in section 3.1 are modified. Where possible, only one parameter is changed in order to fully assess the effect. However, in some instances several parameters are directly linked, and therefore more than one needs to be altered. For example, the supply flow - rate and temperature are linked to maintain a constant cooling load. Three tables are provided at the end of this section (tables 3.4-3.6) as a summary of the simulations modeled and to allow relevant data selection.

3.3.1 Hood Position


Hood position is important for two reasons :

does the position in the laboratory protect or expose the laboratory hood in regard to the room air movement?

does one hood position compared with another significantly impair hood containment performance?



Hood without bulkhead



Hood with bulkhead

Figure 3.04 Hood with and without bulkhead.

3.3.1.1 Single hood positions


To investigate the first question, simulations address a single hood in the open on the long or the short wall as well as a single hood placed in a corner. The three hood positions modeled for the single laboratory hood in both the small and large laboratories are listed in table 3.01. To accommodate this variation the laboratories were re - arranged. A plan view of the layout is shown for large laboratory and small laboratory models in figures 3.05 and 3.06 respectively.

Table 3.01 Description of single hood positions


| Hood Position | Description |
|---------------|------------------------------------|
| 1 | Center of long wall |
| 2 | Sited on long wall close to corner |
| 3 | Center of short wall |

3.3.1.2 Double hood positions


To answer the question about hood interaction, for the small laboratory, simulations are also undertaken for a number of configurations with two laboratory hoods (figures 3.07 to 3.11, table 3.02).



Large laboratory - hood in center of long wall




Large laboratory - hood in corner remote from main door.



Large laboratory - hood in center of short wall opposite main door.

Figure 3.05 Hood positions in large laboratory.



Small laboratory - hood in centre of long wall.



Small laboratory - hood in corner near main door.



Small laboratory - hood in center of long wall.

Figure 3.06 Hood positions in small laboratory.



Small laboratory - two hoods on same wall (2 ft apart).




Small laboratory - two hoods on same wall (4 ft apart)



Small laboratory - two hoods on same wall (6 ft apart)

Figure 3.07 Double hood layout.



Small laboratory - two hoods on same wall (8 ft apart).



Small laboratory - two hoods on opposite walls.



Small laboratory - two hoods on opposite walls (no gaps between sides)
Figure 3.08 Double hood layout.



Small laboratory - two hoods on opposite walls (2 ft apart).



Small laboratory - two hoods on opposite walls (4 ft apart).



Small laboratory - two hoods on opposite walls (6 ft apart)

Figure 3.09 Double hood layout.



Position D10 - D12 only one hood moves.

Small laboratory - two hoods on opposite walls (no gap between sides).



Small laboratory - two hoods on opposite walls (2 ft apart).



Small laboratory - two hoods on opposite walls (4 ft apart)

Figure 3.10 Double hood layout.

Hood 4 ft from corner



Small laboratory - hoods on adjacent perpendicular walls.

Hood 6 ft from corner



Small laboratory - hoods on adjacent perpendicular walls.

Hood 8 ft from corner



Small laboratory - hoods on adjacent perpendicular walls.

Figure 3.11 Double hood layouts

Table 3.02 Description of double hood positions

| Hood Position | Description |
|---------------|---|
| D1 | Two hoods on same wall, 2 feet apart |
| D2 | Two hoods on same wall, 4 feet apart |
| D3 | Two hoods on same wall, 6 feet apart |
| D4 | Two hoods on same wall, 8 feet apart |
| D5 | Two hoods on opposite walls, directly opposite |
| D6 | Two hoods on opposite walls, both moved, 0 feet apart |
| D7 | Two hoods on opposite walls, both moved, 2 feet apart |
| D8 | Two hoods on opposite walls, both moved, 4 feet apart |
| D9 | Two hoods on opposite walls, both moved, 6 feet apart |
| D10 | Two hoods on opposite walls, one moved, 0 feet apart |
| D11 | Two hoods on opposite walls, one moved, 2 feet apart |
| D12 | Two hoods on opposite walls, one moved, 4 feet apart |
| D13 | Two hoods on perpendicular walls. One center of 11 ft wall, second nearest edge 4 ft from corner. |
| D14 | Two hoods on perpendicular walls. One center of 11 ft wall, second nearest edge 6 ft from corner. |
| D15 | Two hoods on perpendicular walls. One center of 11 ft wall, second nearest edge 8 ft from corner. |

3.3.2 Diffuser Types

A number of different types of supply diffusers are modeled (table 3.03). These were selected from catalog data with respect to acceptable flow rates through each diffuser while maintaining a noise level in the range of 35 to 40 dB. In some of the tests the velocity flow rate was significantly altered. For comparison, the basic diffusers were utilized but with the realization that noise criteria, etc., would be exceeded. Before use in the laboratory models each diffuser was tested and compared with manufacturer's throw data by constructing a numerical test module. It was intended that a model as accurate as possible was achieved.

Table 3.03 Diffuser types


| Name | Description |
|------------------|---|
| SQ A | four, 12 inch square diffusers |
| SQ B | two, 24 inch square diffusers |
| SQ C | four, 24 inch square diffusers |
| TAD A | two, 48 inch by 24 inch radial diffusers |
| TAD B | two, 24 inch by 24 inch radial diffusers |
| TAD C | four, 24 inch by 24 inch radial diffusers |
| LAM A | six, 48 inch by 12 inch down - flow diffusers |
| LAM B | four, 48 inch by 24 inch down - flow diffusers |
| DOWN A | four, 24 inch by 24 inch down - flow diffusers |
| DOWN B | four, 24 inch by 48 inch down - flow diffusers |
| PERF A | four, 12 inch by 12 inch perforated diffusers, horizontal throw |
| DISP 1 | fourteen, 24 inch square floor grilles |
| DISP 2 | four, wall displacement units |
| SM SQ A | two, 12 inch square diffusers |
| SM SQ B | one, 24 inch square diffuser |
| SM TAD A | one, 24 inch by 24 inch radial diffuser |
| SM LAM A | two, 48 inch by 12 inch down - flow |
| SM PERF A | two, 12 inch square perforated diffusers, horizontal throw |

The diffuser types were also used in different layouts. A complete list giving all the diffuser layouts is presented (tables 3.04 and 3.05) along with plan views of the diffuser configurations (figures 3.12-3.31). Included in the table are the simulation numbers relating to the particular diffuser layout (see also section 3.3.5).


Table 3.04 Diffuser positions - large laboratory (33ft x 22ft)
(figures 3.12 to 3.23)

| Layout Name | No. / Type / Size | Description | Simulation Nos. |
|-------------|-------------------------|---|------------------------------|
| SQ A.1 | 4 / Square / 12" | Laid out on quarters | 41,43,44,52-58, 76-9,122,142 |
| SQ A.2a | 4 / Square / 12" | Spaced close to end walls | 61 |
| SQ A.2b | 4 / Square / 12" | Spaced close to end walls, quadrants towards walls blanked | 62 |
| SQ A.3 | 4 / Square / 12" | Diffusers staggered | 63 |
| SQ B.1 | 2 / Square / 24" | Staggered spacing | 42,45,46,106, 107,123,143 |
| SQ B.2 | 2 / Square / 24" | Along centerline | 64,86-88 |
| SQ B.3 | 2 / Square / 24" | In line in front of hood, quadrant towards hood blanked | 65 |
| SQ C.1 | 4 / Square / 24" | Spaced close to end walls | 2,10,18 |
| SQ C.2 | 4 / Square / 24" | Laid out on quarters | 3,15,19,25,28,31,33 |
| SQ C.3 | 4 / Square / 24" | Diffusers staggered | 4,11 |
| PERF A.1 | 4 / 12" x 12" | Laid out on quarters | 41b,54b-56b,125, 145 |
| PERF A.2a | 4 / 12" x 12" | Spaced close to end walls | 61b |
| PERF A.3 | 4 / 12" x 12" | Diffusers staggered | 63b |
| DOWN A.1 | 4 / Square 24" | Spaced close to end walls | 7,21,27,30 |
| DOWN A.2 | 4 / Square 24" | Diffusers staggered | 8,14 |
| DOWN B.1 | 4 / 24" x 48" | Spaced close to end walls | 22,24 |
| DOWN B.2 | 4 / 24" x 48" | Diffusers staggered | 23 |
| LAM A.1 | 6 / Down-flow / 48"x12" | Aligned short edge in lines of 3, long edges in direction of long walls | 47,80 |
| LAM A.2 | 6 / Down-flow / 48"x12" | Aligned long edge in lines of 3, long edges in direction of long walls | 66 |
| LAM B.1 | 4 / Down-flow / 48"x12" | Laid out on quarters, long edges | 48,89-91 |


| Layout Name | No. / Type / Size | Description | Simulation Nos. |
|-------------|-------------------------|--|------------------------------------|
| LAM B.2 | 4 / Down-flow / 48"x12" | in line with long walls Spaced close to end walls, long edges in line with long walls | 67 |
| LAM B.3 | 4 / Down-flow / 48"x12" | Diffusers staggered, long edges in line with long walls | 68 |
| TAD A.1 | 2 / Radial / 48"x24" | Along centerline, radial spread across laboratory | 16,17,20,26,29,32,34,49,49c, 92-94 |
| TAD A.2 | 2 / Radial / 48"x24" | Staggered array, radial spread across laboratory | 5,12, 69,69c |
| TAD A.3 | 2 / Radial / 48"x24" | Staggered array, diffusers close to hood, radial spread across laboratory | 6,13, 70,70c |
| TAD B.1 | 2 / Radial / 24"x24" | Along centerline, radial spread across laboratory | 50,50c,81,124, 144,147 |
| TAD B.2 | 2 / Radial / 24"x24" | Staggered array, radial spread across laboratory | 71,71c |
| TAD B.3a | 2 / Radial / 24"x24" | Staggered array, diffusers close to hood, radial spread across laboratory | 72,146 |
| TAD B.3b | 2 / Radial / 24"x24" | Staggered array, diffusers close to hood, radial spread along laboratory | 73 |
| TAD C.1a | 4 / Radial / 24"x24" | Laid out on quarters, radial spread across laboratory | 51 |
| TAD C.1b | 4 / Radial / 24"x24" | Laid out on quarters, radial spread along laboratory | 74 |
| TAD C.2 | 4 / Radial / 24"x24" | Staggered array, radial spread across laboratory | 75,75c |
| DISP 1 | | 14 off 24" floor grilles | 59 |
| DISP 2 | | 4 off standing displacement units | 60 |
| NONE | 3 Free stream | 3 open sides to the hood in isolation model | 0,35-40 |



Diffusers laid out on quarters.




Diffusers spaced close to end walls.




Diffusers close to walls - quadrants towards short walls blanked.


Figure 3.12 Diffuser layout - large laboratory.



Diffuser along centerline.
Figure 3.13 Diffuser layout -large laboratory.



Diffusers in line in front of hood. Quadrant towards hood blanked.




Diffusers spaced close to end walls.


SQC.2

Diffusers laid out on quarters.


Figure 3.14 Diffuser layout -large laboratory.



Staggered arrangement of diffusers




Diffusers laid out on quarters




Diffusers spaced close to end walls


Figure 3.15 Diffuser layout - large laboratory



Diffusers with staggered arrangement.




Diffusers spaced close to wall.




Staggered arrangement of diffusers.


Figure 3.16 Diffuser layout - large laboratory.



Diffusers spaced close to end walls.




Staggered arrangement of diffusers.




Diffusers in lines of three aligned with short wall.


Figure 3.17 Diffuser layout - large laboratory.



Diffusers in lines of three aligned with long wall.




Laid out on quarters, long edge aligned with long wall.




Close to end walls. Long edge aligned with long wall.

Figure 3.18 Diffuser layout - large laboratory.



LAM B.3


Staggered arrangement, long edge aligned with long wall.



TAD A.1

2 x 48" by 24" radial flow


Diffusers along centerline, radial spread across laboratory.




TAD A.2

Staggered arrangement of diffusers.


Figure 3.19 Diffuser layout - large laboratory.



Staggered arrangement with diffusers close to hood. Radial spread across laboratory.




Diffusers along centerline, radial spread across laboratory.




Staggered array, radial spread across laboratory.


Figures 3.20 Diffuser layout - large laboratory.



Staggered arrangement of diffusers - close to hood. Radial spread across laboratory.




Staggered arrangement of diffusers - close to hood. Radial spread along laboratory.




Diffusers laid out on quarters, radial spread across laboratory.


Figure 3.21 Diffuser layout - large laboratory.



Laid out on quarters, radial spread along laboratory.




Staggered diffuser arrangement, radial spread across laboratory.



Fourteen 24" square floor grilles.

Figure 3.22 Diffuser layouts - large laboratory.



Four floor standing displacement units.

Figure 3.23 Diffuser layout - large laboratory.

Table 3.05 Diffuser positions - small laboratory (22ft x 11ft)
(figures 3.24 to 3.31)


| Layout Name | No. / Type / Size | Description | Simulation Nos. |
|-------------|-------------------|--|---|
| SM SQ A.1 | 2 / Square / 12" | Even jet throw along centerline | 82,82c,110,110c,118,118c,126,126c,130,130c,134,138,139,139c,148,153,155,183,184,193 |
| SM SQ A.2a | 2 / Square / 12" | Staggered | 102,102c,103, 148,149 |
| SM SQ B.1 | 1 / Square / 24 | On center line, away from main door | 83,83c,119,119c,127,127c,131,131c,135,135c,139,140,140c,150,179,185 |
| SM SQ B.2 | 1 / Square / 24 | On centerline, close to main door | 104,104c |
| SM SQ B.3 | 1 / Square / 24 | On centerline, in front of hood | 112,113,113c,189,190 |
| SM SQ B.3b | 1 / Square / 24 | On centerline, in front of hood, quadrant towards hood blanked | 105,105c,111,111c,151 |
| SM SQ B3c | 1 / Square / 24 | | 191 |
| SM SQ B3d | 1 / Square / 24 | 1 foot further away from hood than SM SQ B3 1 foot nearer to hood than SM SQ B3 | 192 |

| Layout Name | No. / Type / Size | Description | Simulation Nos. |
|-------------|--------------------------|---|---|
| SM SQ B4 | 2 / Square / 24 | Between SM SQ B.1 and SM SQ B.3 | 188 |
| SM LAM A.1 | 2 / Down-flow / 48"x12" | Arranged either side of hood, long edge across laboratory | 84,84c |
| SM LAM A.2 | 2 / Down-flow / 48"x12" | Along centerline, long edge along laboratory | 98,98c |
| SM LAM A.3 | 2 / Down-flow / 48"x12" | Staggered, long edge along laboratory | 99,99c |
| SM LAM A.4 | 2 / Down-flow / 48"x12" | In line in front of hood, long edge along laboratory | 100,100c |
| SM LAM A.5 | 2 / Down-flow / 48"x12" | Close to hood sides, long edge across laboratory | 101,101c |
| SM TAD A.1a | 1 / Radial / 24"x24" | On centerline away from main door, radial spread across laboratory | 85,85c,108,108c,109,109c,181 |
| SM TAD A.1b | 1 / Radial / 24"x24" | On centerline away from main door, radial spread along laboratory | 97,97c,114,115,154 |
| SM TAD A.2a | 1 / Radial / 24"x24" | On centerline close to main door, radial spread across laboratory | 95,95c,180 |
| SM TAD A.2b | 1 / Radial / 24"x24" | On centerline close to main door, radial spread along laboratory | 96,96c |
| SM TAD A.3 | 1 / Radial / 24"x24" | Centered in front of the hood | 116,116c,117,117c,120,120c,128,128c,132,132c,136,136c,152,186 |
| SM PERF A.1 | 2 / Perforated / 12"x12" | On centerline along laboratory at $\frac{1}{4}$ and $\frac{3}{4}$ | 84b,121,129,133,133c,137,141,182,187 |
| SM PERF A.2 | 2 / Perforated / 12"x12" | Staggered at $\frac{1}{4}$ and $\frac{3}{4}$ along length of laboratory | 99b |
| SM PERF A.3 | 2 / Perforated / 12"x12" | Staggered close to hood sides | 101b |



2 x 12" square

Diffusers along centerline



Staggered arrangement of diffusers



1 x 24" square

Diffuser on centerline away from main door


Figure 3.24 Diffuser layout - small laboratory.



Diffuser on centerline close to main door.




Diffuser on centerline in front of hood.



Diffuser on centerline in front of hood, quadrant towards hood blanked.


Figure 3.25 Diffuser layout - small laboratory.



1 foot further away from hood than SM SQ B.3



1 foot closer to hood than SM SQ B.3




Two diffusers on centerline (to facilitate use of two hoods)

Figure 3.26 Diffuser layout - small laboratory.




Diffuser on centerline, just to one side of hood.



2 x 48" x 12" laminar flow

Diffuser each side of hood, long side across laboratory.



Diffusers each side of hood, long side along laboratory.


Figure 3.27 Diffuser layout - small laboratory.



Staggered arrangement, long side along laboratory.



Diffusers both in line in front of hood.




Diffusers close to hood sides, long sides across laboratory.
Figure 3.28 Diffuser layout - small laboratory.



1 x 24" by 24" radial flow

On centerline, remote from main door, radial spread across laboratory




As SM TAD A.1a with diffuser rotated 90°




On centerline, near to main door, radial spread across laboratory.

Figure 3.29 Diffuser layout - small laboratory.



As SM TAD A.2a with diffuser rotated 90°.



Diffuser centered in front of hood, radial spread across laboratory.



2 x 12" square perforated

Diffusers on centerline of laboratory.

Figure 3.30 Diffuser layout - small laboratory.



Staggered arrangement of diffusers.



Staggered arrangement with diffusers close to hood.

Figure 3.31 Diffuser layout - small laboratory.

3.3.3 Heating, Ventilating, and Air Conditioning

As well as changing the diffuser type, many of the HVAC parameters were modified to assess sensitivity. The changes relating to effects on the ventilation system can be summarized as follows :

The ventilation rate through the supply air diffusers varies between 6.0 and 34.7 air changes per hour (ACH).

Supply air temperature varies between 50°F (10.0°C) and 63.5°F (17.5°C).

Heat load varies between 5.16 W/sq. ft and 12 W/sq. ft.

Make up air is introduced through door crack(s) and / or a transfer grille and is assumed to be at the ambient temperature of the adjacent space of 72°F (22.2°C) with a variation in quantity from none to 542 cfm.

3.3.4 Scientist in Front of the Hood

In a number of the simulations, a scientist is present in front of the laboratory hood. In particular, all the simulations with the letter “c” after the name (for example run049c) simulate a scientist in front of the hood. Additionally, the duct - work from the fume hood and the lighting are recessed into a false ceiling. The other details, (such as heat load, ventilation rate, etc.) match those of the original run without the additional letter (for example run049)

3.3.5 Simulations Performed

The hundreds of simulations performed represent different parametric changes in order to compare performance. The tables presented are to describe the differences between the individual cases:

Tables 3.04 and 3.05. These tables, presented previously in this section, detail the diffuser layouts for the large and small laboratories respectively. For each layout the simulations numbers using that layout are given.

Table 3.06. This table details in numerical order every simulation performed. The table gives the general parameters used and difference to the base - line model for each diffuser type. This table matches the appendix where input data and results are presented in numerical order for every simulation undertaken.

Table 3.07. For a number of global parameters (for example supply temperature) this table gives the associated simulation numbers for the large or small laboratory. This table helps the reader to find cases that match a particular parameter. Full details of the cases can then be found in the appendix, which is presented with the simulations in numerical order.

Table 3.06 Simulations

Unless otherwise stated in table 3.06, the simulations use the following common parameters:

Hood face velocity is 100 fpm

Diffuser layouts prefixed by "SM" refer to simulations using the small laboratory model

The notes column in table 3.06 represents changes from a 'base - line' model for that diffuser type.

Simulations (runs) marked with the letter "b" (for example run054b) are for a perforated diffuser (configured to blow horizontally across the ceiling in four distinct jets) replacing the original diffuser type. In the case of run054b the perforated diffusers replace the square diffusers of run054.

Simulations (runs) marked with the letter "c" (for example run049c) have a representation of a scientist four inches in front of the sash opening. In addition the ductwork from the fume hood and the lighting units are assumed to be recessed into a false ceiling. In the basic case (say for example run049) the entry to the hood is unrestricted and the lights are suspended below the ceiling. The duct removing air from the fume hood is below ceiling level.

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| 000 | na | isol. | na | na | Hood in isolation; basic reference case used in analysis, hood face velocity 100 fpm |
| 001 | na | 1 | 8.1 | 53 | Ventilation system over whole ceiling. Hood face velocity 50 fpm |
| 002 | SQ C.1 | 1 | 8.1 | 53 | 4 off square 24" diffusers. Hood face velocity 50 fpm |
| 003 | SQ C.2 | 1 | 8.1 | 53 | 4 off square diffusers (placed so that distance from end wall to diffuser center line = one quarter length of room). Hood 50 fpm |
| 004 | SQ C.3 | 1 | 8.1 | 53 | 4 off square diffusers (placed such that a diffuser is close to the fume hood).Hood 50 fpm |
| 005 | TAD A.2 | 1 | 8.1 | 53 | 2 off 2' x 4' TAD radial diffusers placed asymmetrically so that diffuser to hood dimension large. Hood 50 fpm |
| 006 | TAD A.3 | 1 | 8.1 | 53 | 2 off 2' x 4' TAD radial diffusers placed asymmetrically so that diffuser to hood dimension relatively small. Hood 50 fpm |
| 007 | DOWN A.1 | 1 | 8.1 | 53 | 4 off downward air flow from 24" square ceiling grilles |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| 008 | DOWN A.2 | 1 | 8.1 | 53 | 4 off downward air flow from 24" square ceiling grilles |
| 009 | na | 1 | 8.1 | 53 | Run 001 hood velocity 100 fpm |
| 010 | SQ C.1 | 1 | 8.1 | 53 | Fume hood face velocity increased to 100 fpm |
| 011 | SQ C.3 | 1 | 8.1 | 53 | Fume hood face velocity increased to 100 fpm |
| 012 | TAD A.2 | 1 | 8.1 | 53 | Run 005 hood velocity 100 fpm |
| 013 | TAD A.3 | 1 | 8.1 | 53 | Run 006 hood velocity 100 fpm |
| 014 | DOWN A.2 | 1 | 8.1 | 53 | Hood velocity 100 fpm, downward air flow from one of the positions in runs 007 and 008 |
| 015 | SQ C.2 | 1 | 10.0 | 58.8 | As run 003 increase flow rate to 10 ACH and increase supply air temperature. Hood 50 fpm |
| 016 | TAD A.1 | 1 | 8.1 | 53 | 2 off TAD diffusers on centerline. Hood 50 fpm |
| 017 | TAD A.1 | 1 | 8.1 | 53 | Run 16 - hood face velocity 100 fpm |
| 018 | SQ C.1 | 1 | 8.1 | 53 | Close door and set such that room supply is exactly matched with exhaust and fume hood. Hood 50 fpm. |
| 019 | SQ C.2 | 1 | 8.1 | 53 | Close door and set such that room supply is exactly matched with exhaust and fume hood. Hood 50 fpm |
| 020 | TAD A.1 | 1 | 8.1 | 53 | Close door and set such that room supply is exactly matched with exhaust and fume hood. Hood 50 fpm |
| 021 | DOWN A.1 | 1 | 8.1 | 53 | Close door and set such that room supply is exactly matched with exhaust and fume hood. Hood 50 fpm |
| 022 | DOWN B.1 | 1 | 8.1 | 53 | Double size of down-flow grilles (2' x 4'), hood 50 fpm (as Run 007) |
| 023 | DOWN B.2 | 1 | 8.1 | 53 | Double size of down-flow grilles (2' x 4'), hood 50 fpm (as Run 008) |
| 024 | DOWN B.1 | 1 | 8.1 | 53 | Double size of down-flow grilles (2' x 4'), hood 100 fpm (as Run 014) |
| 025 | SQ C.2 | 1 | 8.1 | 53 | Reduce hood opening to 25%, maintain hood face velocity of 50 fpm via bypass |
| 026 | TAD A.1 | 1 | 8.1 | 53 | Reduce hood opening to 25%, maintain hood face velocity of 50 fpm via bypass |
| 027 | DOWN A.1 | 1 | 8.1 | 53 | Reduce hood opening to 25%, maintain hood face velocity of 50 fpm via bypass |
| 028 | SQ C.2 | 1 | 8.1 | 62.3 | Reduce equipment gain to a half and increase supply air temperature |
| 029 | TAD A.1 | 1 | 8.1 | 62.3 | Reduce equipment gain to a half and increase supply air temperature |
| 030 | DOWN A.1 | 1 | 8.1 | 62.3 | Reduce equipment gain to a half and increase supply air temperature |
| 031 | SQ C.2 | 1 | 8.1 | 53 | Add person (as physical obstruction) in front of hood. Hood 50 fpm |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| 032 | TAD A.1 | 1 | 8.1 | 53 | Add person (as physical obstruction) in front of hood. Hood 50 fpm |
| 033 | SQ C.2 | 1 | 8.1 | 53 | Add person + trolley & equipment in front of hood. 1 run with square diffuser. Hood 50 fpm |
| 034 | TAD A.1 | 1 | 8.1 | 53 | Add person + trolley & equipment in front of hood. 1 run with square diffuser. Hood 50 fpm |
| 035 | na | na | na | na | Investigation on fume hood air flow Exhaust from back baffle position, and various positions up duct system to investigate effect on face air flow distribution. Runs carried out without thermal effects in a simple test cell. Hood face velocity 50 fpm |
| 036 | na | na | na | na | |
| 037 | na | na | na | na | |
| 038 | na | na | na | na | |
| 039 | na | na | na | na | Fume hood in isolation, isothermal. 25% open with by pass as large hole. Hood 50 fpm |
| 040 | na | na | na | na | Fume hood in isolation, isothermal. 100% open person in front. Hood 50 fpm |
| 041 | SQ A.1 | 1 | 9.1 | 55 | Base-line model |
| 041b | PERF A.1 | 1 | 9.1 | 55 | Base-line model |
| 042 | SQ B.1 | 1 | 9.1 | 55 | Base-line model |
| 043 | SQ A.1 | 1 | 9.1 | 55 | Person 4 inches in front of hood |
| 044 | SQ A.1 | 1 | 9.1 | 55 | Person 6 inches in front of hood |
| 045 | SQ B.1 | 1 | 9.1 | 55 | Person 4 inches in front of hood |
| 046 | SQ B.1 | 1 | 9.1 | 55 | Person 6 inches in front of hood |
| 047 | LAM A.1 | 1 | 9.1 | 55 | Base-line model |
| 048 | LAM B.1 | 1 | 9.1 | 55 | Base-line model |
| 049 | TAD A.1 | 1 | 9.1 | 55 | Base-line model |
| 049c | TAD A.1 | 1 | 9.1 | 55 | As run049: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 050 | TAD B.1 | 1 | 9.1 | 55 | Base-line model |
| 050c | TAD B.1 | 1 | 9.1 | 55 | As run050: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 051 | TAD C.1a | 1 | 9.1 | 55 | Base-line model |
| 052 | SQ A.1 | 1 | 9.1 | 55 | Decrease jet thickness such that initial jet velocity doubled |
| 053 | SQ A.1 | 1 | 9.1 | 55 | Increase initial jet thickness such that initial jet velocity halved |
| 054 | SQ A.1 | 1.2 | 9.1 | 55 | Completely box in region above hood - bulkhead |
| 054b | PERF A.1 | 1.2 | 9.1 | 55 | Completely box in region above hood - bulkhead |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|---|
| 055 | SQ A.1 | 2 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 055b | PERF A.1 | 2 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 056 | SQ A.1 | 3 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 056b | PERF A.1 | 3 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 057 | SQ A.1 | 1 | 13.6 | 55 | Increase heat load to 12 W/ft ² . Maintain supply temperature mass flow rate increases |
| 058 | SQ A.1 | 1 | 18.1 | 63.5 | Increase supply temperature - mass flow rate will also increase |
| 059 | DISP 1 | 1 | 18.1 | 63.5 | "Displacement system"; lower temperature difference, mass flow rate increased. |
| 060 | DISP 2 | 1 | 18.1 | 63.5 | "Displacement system"; lower temperature difference, mass flow rate increased. |
| 061 | SQ A.2a | 1 | 9.1 | 55 | Base-line model |
| 061b | PERF A.2a | 1 | 9.1 | 55 | Base-line model |
| 062 | SQ A.2b | 1 | 9.1 | 55 | Part of diffuser blanked off (towards wall) |
| 063 | SQ A.3 | 1 | 9.1 | 55 | Base-line model |
| 063b | PERF A.3 | 1 | 9.1 | 55 | Base-line model |
| 064 | SQ B.2 | 1 | 9.1 | 55 | Base-line model |
| 065 | SQ B.3 | 1 | 9.1 | 55 | Part of diffuser pointing towards hood blanked off |
| 066 | LAM A.2 | 1 | 9.1 | 55 | Base-line model |
| 067 | LAM B.2 | 1 | 9.1 | 55 | Base-line model |
| 068 | LAM B.3 | 1 | 9.1 | 55 | Base-line model |
| 069 | TAD A.2 | 1 | 9.1 | 55 | Base-line model |
| 069c | TAD A.2 | 1 | 9.1 | 55 | As run069: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 070 | TAD A.3 | 1 | 9.1 | 55 | Base-line model |
| 070c | TAD A.3 | 1 | 9.1 | 55 | As run070: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 071 | TAD B.2 | 1 | 9.1 | 55 | Base-line model |
| 071c | TAD B.2 | 1 | 9.1 | 55 | As run071: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 072 | TAD B.3a | 1 | 9.1 | 55 | Base-line model |
| 072c | TAD B.3a | 1 | 9.1 | 55 | As run072: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 073 | TAD B.3b | 1 | 9.1 | 55 | Diffusers rotated through 90° compared to layout TAD B.3a |
| 073c | TAD B.3b | 1 | 9.1 | 55 | As run073: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 074 | TAD C.1b | 1 | 9.1 | 55 | Diffusers rotated through 90° compared to layout TAD C.1a |
| 074c | TAD C.1b | 1 | 9.1 | 55 | As run074: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 075 | TAD C.2 | 1 | 9.1 | 55 | Base-line model |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| 075c | TAD C.2 | 1 | 9.1 | 55 | As run075: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 076 | SQ A.1 | 1 | 9.1 | 55 | Door cracks under all doors |
| 077 | SQ A.1 | 1 | 9.1 | 55 | Door crack sealed, transfer grille above main door |
| 078 | SQ A.1 | 1 | 9.1 | 55 | Door crack sealed, transfer grille above door nearest hood |
| 079 | SQ A.1 | 1 | 9.1 | 55 | Door crack sealed, transfer grille above door. Increase exhaust through dropper to increase flow through transfer to 200 cfm |
| 080 | LAM A.1 | 1 | 9.1 | 55 | Door crack sealed, transfer grille above main door |
| 081 | TAD B.1 | 1 | 9.1 | 55 | Door crack sealed, transfer grille above main door |
| 082 | SM SQ A.1 | 1 | 9.1 | 55 | Base-line model |
| 082c | SM SQ A.1 | 1 | 9.1 | 55 | As run082: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 083 | SM SQ B.1 | 1 | 9.1 | 55 | Base-line model |
| 083c | SM SQ B.1 | 1 | 9.1 | 55 | As run083: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 084 | SM LAM A.1 | 1 | 9.1 | 55 | Base-line model |
| 084b | SM PERF A.1 | 1 | 9.1 | 55 | Base-line model |
| 084c | SM LAM A.1 | 1 | 9.1 | 55 | As run084: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 085 | SM TAD A.1a | 1 | 9.1 | 55 | Base-line model |
| 085c | SM TAD A.1a | 1 | 9.1 | 55 | As run085: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 086 | SQ B.2 | 1.2 | 9.1 | 55 | Completely box in region above hood - bulkhead |
| 087 | SQ B.2 | 2 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 088 | SQ B.2 | 3 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 089 | LAM B.1 | 1.2 | 9.1 | 55 | Completely box in region above hood - bulkhead |
| 090 | LAM B.1 | 2 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 091 | LAM B.1 | 3 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 092 | TAD A.1 | 1.2 | 9.1 | 55 | Completely box in region above hood - bulkhead |
| 093 | TAD A.1 | 2 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 094 | TAD A.1 | 3 | 9.1 | 55 | Move hood and re-arrange laboratory |
| 095 | SM TAD A.2a | 1 | 9.1 | 55 | Base-line model |
| 095c | SM TAD A.2a | 1 | 9.1 | 55 | As run095: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 096 | SM TAD A.2b | 1 | 9.1 | 55 | Base-line model |
| 096c | SM TAD A.2b | 1 | 9.1 | 55 | As run096: person 4 inches in front of hood, |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|---|
| | | | | | ductwork and lighting recessed into ceiling |
| 097 | SM TAD A.1b | 1 | 9.1 | 55 | Base-line model |
| 097c | SM TAD A.1b | 1 | 9.1 | 55 | As run097: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 098 | SM LAM A.2 | 1.2 | 9.1 | 55 | Base-line model |
| 098c | SM LAM A.2 | 1.2 | 9.1 | 55 | As run098: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 099 | SM LAM A.3 | 1 | 9.1 | 55 | Base-line model |
| 099b | SM PERF A.2 | 1 | 9.1 | 55 | Base-line model |
| 099c | SM LAM A.3 | 1 | 9.1 | 55 | As run099: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 100 | SM LAM A.4 | 1 | 9.1 | 55 | Base-line model |
| 100c | SM LAM A.4 | 1 | 9.1 | 55 | As run100: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 101 | SM LAM A.5 | 1 | 9.1 | 55 | Base-line model |
| 101b | SM PERFA.3 | 1 | 9.1 | 55 | Base-line model |
| 101c | SM LAM A.5 | 1 | 9.1 | 55 | As run101: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 102 | SM SQ A.2 | 1 | 9.1 | 55 | Base-line model |
| 102c | SM SQ A.2 | 1 | 9.1 | 55 | As run102: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 103 | SM SQ A.2 | 1.2 | 9.1 | 55 | Bulkhead fitted above hood |
| 103c | SM SQ A.2 | 1.2 | 9.1 | 55 | As run103: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 104 | SM SQ B.2 | 1 | 9.1 | 55 | Base-line model |
| 104c | SM SQ B.2 | 1 | 9.1 | 55 | As run104: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 105 | SM SQ B.3b | 1 | 9.1 | 55 | Side towards hood blanked off |
| 105c | SM SQ B.3b | 1 | 9.1 | 55 | As run105: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 106 | SQ B.1 | 3 | 9.1 | 55 | Double module, hood position 3, transfer grilles above side door near hood (supply velocity 1.3 m/s) |
| 107 | SQ B.1 | 1 | 9.1 | 55 | Double module, hood position 1. Door with transfer grille moved closer to wall with hood. |
| 108 | SM TAD A.1a | 1 | 9.1 | 55 | Move transfer grille along current wall away from hood |
| 108c | SM TAD A.1a | 1 | 9.1 | 55 | As run108: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 109 | SM TAD A.1a | 1 | 10.0 | 57 | Increase supply flow compensating the supply temperature accordingly. Reduce air flow through transfer grille |
| 109c | SM TAD A.1a | 1 | 10.0 | 57 | As run109: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|---|
| 110 | SM SQ A.1 | 1 | 10.0 | 57 | Increase supply flow compensating the supply temperature accordingly. Reduce air flow through transfer grille (supply velocity 1.5 m/s) |
| 110c | SM SQ A.1 | 1 | 10.0 | 57 | As run110: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 111 | SM SQ B.3b | 1 | 9.1 | 55 | Supply velocity 0.9 m/s. Side towards hood blanked |
| 111c | SM SQ B.3b | 1 | 9.1 | 55 | As run111: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 112 | SM SQ B.3a | 1 | 9.1 | 55 | As 111, but with all four sides active |
| 112c | SM SQ B.3a | 1 | 9.1 | 55 | As run112: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 113 | SM SQ B.3a | 1 | 9.1 | 55 | As 112, but with bulkhead above hood |
| 113c | SM SQ B.3a | 1 | 9.1 | 55 | As run113: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 114 | SM TAD A.1b | 2 | 9.1 | 55 | Hood moved towards door |
| 115 | SM TAD A.1b | 3 | 9.1 | 55 | Hood moved to end wall opposite door |
| 116 | SM TAD A.3 | 1 | 9.1 | 55 | Radial diffuser in front of hood - blowing towards hood |
| 116c | SM TAD A.3 | 1 | 9.1 | 55 | As run116: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 117 | SM TAD A.3 | 1 | 9.1 | 55 | As 116 with bulkhead above hood |
| 117c | SM TAD A.3 | 1 | 9.1 | 55 | As run117: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 118 | SM SQ A.1 | 1 | 17.0 | 63 | Transfer grille closed and extra air supplied through diffusers. Supply temperature calculated based on standard heat gains |
| 118c | SM SQ A.1 | 1 | 17.0 | 63 | As run118: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 119 | SM SQ B.1 | 1 | 17.0 | 63 | Transfer grille closed and extra air supplied through diffusers. Supply temperature calculated based on standard heat gains |
| 119c | SM SQ B.1 | 1 | 17.0 | 63 | As run119: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 120 | SM TAD A.3 | 1 | 17.0 | 63 | Transfer grille closed and extra air supplied through diffusers. Supply temperature calculated based on standard heat gains |
| 120c | SM TAD A.3 | 1 | 17.0 | 63 | As run120: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 121 | SM PERF A.1 | 1 | 17.0 | 63 | Transfer grille closed and extra air supplied through diffusers. Supply temperature calculated based on standard heat gains |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|---|
| 121c | SM PERF A.1 | 1 | 17.0 | 63 | As run121: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 122 | SQ A.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature |
| 123 | SQ B.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature |
| 124 | TAD B.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature |
| 125 | PERF A.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature |
| 126 | SM SQ A.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 126c | SM SQ A.1 | 1 | 6.0 | 55 | As run126: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 127 | SM SQ B.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 127c | SM SQ B.1 | 1 | 6.0 | 55 | As run127: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 128 | SM TAD A.3 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 128c | SM TAD A.3 | 1 | 6.0 | 55 | As run128: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 129 | SM PERF A.1 | 1 | 6.0 | 55 | Heat load reduced so that SUPPLY air change rate = 6 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 129c | SM PERF A.1 | 1 | 6.0 | 55 | As run129: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 130 | SM SQ A.1 | 1 | 12.0 | 55 | Heat load increased so that SUPPLY air change rate = 12 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 130c | SM SQ A.1 | 1 | 12.0 | 55 | As run130: person 4 inches in front of hood, |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|---|
| | | | | | ductwork and lighting recessed into ceiling |
| 131 | SM SQ B.1 | 1 | 12.0 | 55 | Heat load increased so that SUPPLY air change rate = 12 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 131c | SM SQ B.1 | 1 | 12.0 | 55 | As run131: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 132 | SM TAD A.3 | 1 | 12.0 | 55 | Heat load increased so that SUPPLY air change rate = 12 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 132c | SM TAD A.3 | 1 | 12.0 | 55 | As run132: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 133 | SM PERF A.1 | 1 | 12.0 | 55 | Heat load increased so that SUPPLY air change rate = 12 ACH while maintaining same supply temperature. Make up air through transfer grille at ambient temperature |
| 133c | SM PERF A.1 | 1 | 12.0 | 55 | As run133: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 134 | SM SQ A.1 | 1 | 9.1 | 50 | Supply temperature reduced - load calculated based upon 9.1 ACH. Make up air through transfer grille at ambient temperature |
| 134c | SM SQ A.1 | 1 | 9.1 | 50 | As run134: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 135 | SM SQ B.1 | 1 | 9.1 | 50 | Supply temperature reduced - load calculated based upon 9.1 ACH. Make up air through transfer grille at ambient temperature |
| 135c | SM SQ B.1 | 1 | 9.1 | 50 | As run135: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 136 | SM TAD A.3 | 1 | 9.1 | 50 | Supply temperature reduced - load calculated based upon 9.1 ACH. Make up air through transfer grille at ambient temperature |
| 136c | SM TAD A.3 | 1 | 9.1 | 50 | As run136: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 137 | SM PERF A.1 | 1 | 9.1 | 50 | Supply temperature reduced - load calculated based upon 9.1 ACH. Make up air through transfer grille at ambient temperature |
| 137c | SM PERF A.1 | 1 | 9.1 | 50 | As run137: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 138 | SM SQ A.1 | 3 | 9.1 | 55 | Move hood, re-arrange laboratory |
| 139 | SM SQ A.1 | 1.2 | 9.1 | 55 | Bulkhead fitted above hood |
| 139c | SM SQ A.1 | 1.2 | 9.1 | 55 | As run139: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 140 | SM SQ B.1 | 1.2 | 9.1 | 55 | Bulkhead fitted above hood |
| 140c | SM SQ B.1 | 1.2 | 9.1 | 55 | As run140: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| 141 | SM PERF A.1 | 1.2 | 9.1 | 55 | Bulkhead fitted above hood |
| 141c | SM PERF A.1 | 1.2 | 9.1 | 55 | As run141: person 4 inches in front of hood, ductwork and lighting recessed into ceiling |
| 142 | SQ A.1 | 1.4 | 9.1 | 55 | Trunk exhaust moved to opposite end of room |
| 143 | SQ B.1 | 1.4 | 9.1 | 55 | Trunk exhaust moved to opposite end of room |
| 144 | TAD B.1 | 1.4 | 9.1 | 55 | Trunk exhaust moved to opposite end of room |
| 145 | PERF A.1 | 1.4 | 9.1 | 55 | Trunk exhaust moved to opposite end of room |
| 146 | TAD B.3a | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 147 | TAD B.1 | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 148 | SM SQ A.1 | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 149 | SM SQ A.2 | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 150 | SM SQ B.1 | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 151 | SM SQ B.3b | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 152 | SM TAD A.3 | 1 | 9.1 | 55 | Person 4 inches from hood face |
| 153 | SM SQ A.1 | 2 | 9.1 | 55 | Person 4 inches from hood face |
| 154 | SM TAD A.1b | 3 | 9.1 | 55 | Person 4 inches from hood face |
| 155 | SM SQ A.1 | 3 | 9.1 | 55 | Person 4 inches from hood face |
| 156 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 2 foot apart |
| 157 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 2 foot apart |
| 158 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 4 foot apart |
| 159 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 4 foot apart Diffuser blowing towards hood - side blanked |
| 160 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 4 foot apart |
| 161 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 4 foot apart Diffuser blowing towards hood side blanked |
| 162 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 6 foot apart |
| 163 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 6 foot apart Diffuser blowing towards hood - side blanked |
| 164 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 6 foot apart |
| 165 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 6 foot apart Diffuser blowing towards hood - side blanked |
| 166 | SM SQ B.4 | | 27.3 | 60.8 | Two hoods on same wall, 8 foot apart |
| 167 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on same wall, 8 foot apart |
| 168 | SM SQ B.4 | | 34.7 | 63.1 | Two hood directly opposite across width of laboratory |
| 169 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, both moved, edges line up |
| 170 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, both moved, gap 2 ft |
| 171 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, both moved, gap 4 ft |
| 172 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, both moved, gap 6 ft |
| 173 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, one moved, edges line up |
| 174 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, one moved, gap 2 ft |
| 175 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods opposite, one moved, gap 4 ft |
| 176 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on perpendicular walls. One center |

| Run no. | Diffuser Layout | Hood Posn | Supp ACH | Supp temp (°F) | Notes |
|---------|-----------------|-----------|----------|----------------|--|
| | | | | | of 11 ft wall, second nearest edge 4 ft from corner |
| 177 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on perpendicular walls. One center of 11 ft wall, second nearest edge 6 ft from corner |
| 178 | SM SQ B.4 | | 34.7 | 63.1 | Two hoods on perpendicular walls. One center of 11 ft wall, second nearest edge 8 ft from corner |
| 179 | SM SQ B.1 | 2 | 9.1 | 55 | All parameters except hood position are the same as in run083 |
| 180 | SM TAD A.2a | 2 | 9.1 | 55 | All parameters except hood position are the same as in run095 |
| 181 | SM TAD A.1a | 2 | 9.1 | 55 | All parameters except hood position are the same as in run085 |
| 182 | SM PERF A.1 | 2 | 9.1 | 55 | All parameters except hood position are the same as in run084b |
| 183 | SM SQ A.1 | 2 | 9.1 | 55 | All parameters except hood position are the same as in run082 |
| 184 | SM SQ A.1 | 2 | 17.0 | 63 | All parameters except hood position are the same as in run118 |
| 185 | SM SQ B.1 | 2 | 17.0 | 63 | All parameters except hood position are the same as in run119 |
| 186 | SM TAD A.3 | 2 | 17.0 | 63 | All parameters except hood position are the same as in run120 |
| 187 | SM PERF A.1 | 2 | 17.0 | 63 | All parameters except hood position are the same as in run121 |
| 188 | SM SQ B.5 | 1 | 17.0 | 63 | Transfer grille shut, diffuser in position between SM SQ B.1 & SM SQ B.3 |
| 189 | SM SQ B.3a | 1 | 17.0 | 63 | Transfer grille shut - diffuser in front of hood, no blanking |
| 190 | SM SQ B.3a | 1.2 | 17.0 | 63 | The same as run189 except bulkhead fitted |
| 191 | SM SQ B.3c | 1.2 | 17.0 | 63 | Diffuser moved 1 ft away from hood (c.f. SM SQ B.3), bulkhead fitted above hood |
| 192 | SM SQ B.3d | 1.2 | 17.0 | 63 | Diffuser moved 1 ft nearer to hood (c.f. SM SQ B.3), bulkhead fitted above hood |
| 193 | SM SQ A.1 | 1 | 15.2 | 61.9 | Single hood with modified supply rates for double hood comparison |

Table 3.07 Reference configurations

| Simulations | Large Laboratory 33ft x 22ft | Small Laboratory 22ft x 11ft |
|----------------------------------|--|---|
| Diffuser : | | |
| Conventional | 2-4,10,11,15,18,19,25,28,31,33,41-46,52-58,61-65,76-79,86-88,106-107,122,123,142-143 | 82,82c,83,83c,102-105,102c-105c,110-113,110c-113c,118-119,118c-119c,126,126c,127,127c,130-131,130c-131c,134-135,134c-135c,138-140,139c-140c,148-151,153,156-179,183-185,188-193 |
| Perforated (horizontal throw) | 41b,54b-56b,61b,63b,125,145 | 84b,99b,101b,121,121c,129,129c,133,133c,137,137c,182,187 |
| Perforated (downward throw) | 7,8,14,21-24,27,30 | |
| Laminar | 1 ² , 9 ² ,47,48,66-68, 80,84,84c,89-91 | 84,84c,98-101,98c-101c |
| Radial (TAD) | 5,6,12,13,16,17,20,26,29,32,34,49-51,49c,50c,69-75,69c-75c,81,92-94,124,144,146,147 | 85,85c,95-97,95c-97c,108-109,108c-109c,114-117,116c,117c,120,120c,128,128c,132,132c,136,136c,152,154,180,181,186 |
| Displacement | 59,60 | |
| None | 0,35-40 | 0,35-40 |
| Temperature : | | |
| 50.0 °F/10.0 °C | | 134-137,134-137c |
| 53.0 °F/11.7 °C | 1-14,16-27,31-34 | |
| 55.0 °F/12.7 °C | 41-57,41b,49c,50c,54b,55b,61-81,61b,63b,69c-75c,86-94,106-107,122-125,142-147 | 82-85,84b,82c-85c,95,105,99b,101b, 95c-105c,108,108c,111-117,126-133,126c-133c,138-141, 139c-141c,148-155 |
| 57.0 °F/13.9 °C | | 109,109c,110,110c |
| 58.8 °F/14.9 °C | 15 | |
| 60.8 °F/16.0 °C | | 156,158,159,162,163,166 |
| 61.9 °F/16.6 °C | | 193 |
| 62.3 °F/16.8 °C | 28-30 | |
| 63.0 °F/17.2 °C | | |
| 63.5 °F/17.5 °C | 58-60 | 118-121,118c-121c,157,160,161,164,165,167-178,184-192 |

| Simulations | Large Laboratory 33ft x 22ft | Small Laboratory 22ft x 11ft |
|----------------------|---|---|
| Ventilation Rate : | | |
| 6.0 ach | 122-125 | 126-129,126c-129c |
| 8.1 ach | 1-14,16-34 | |
| 10.0 ach | 15 | |
| 9.1 ach | 41-56,41b,49c,50c,54b-56b,61-81, 61b,63b,69c-75c,86-94,106- 107,142-147 | 82-85,82c-85c,95-105,95c- 105c,108, 111-117,111c-113c,116c- 117c,134-141,134c-137c,139c- 141c,148-155, 179-183 |
| 10.0 ach | 15 | |
| 12.0 ach | | 130-133,130c-133c |
| 13.6 ach | 57 | |
| 15.2 ach | | 193 |
| 17.0 ach | | 118-121,118c-121c,184-192 |
| 18.1 ach | 58-60 | |
| 27.3 ach | | 156,158,159,162,163,166 |
| 34.7ach | | 157,160,161,164,165,167-178 |
| Hood Face Velocity : | | |
| 50 fpm, 25% open | 25-27 | |
| 50 fpm | 1-8,15,16,18-23,27-40 | |
| 100 fpm | 0,9-14,17,24,41- 81,41b,49c,50c,54b- 56b,61b,63b,69c-75c,86-94,106- 107, 122-125,142-147 | 82-85,82c-85c,95-105,95c- 105c,108-121,108c-113c,116c- 118c,126-141, 126c-137c,139c- 141c,148-193 |
| Hood Position : | | |
| Hood in Isolation | 0,35-40 | 0,35-40 |
| Long Wall | 1-34,41-53,41b,49c,50c,57- 81,61b,63b, 69c-75c,107,122- 125,142-147 | 82-85,82c-85c,95-97,95c-97c,99- 102,99b,99c-102c,101b,104,104c, 105,105c,108-113,108c-113c,116- 121, 116c-121c,126-141,126c-137c, 139c-141c,148-152,188-189,193 |
| Long Wall - Corner | 55,55b,87,90,93 | 114,153,179-187 |

| Simulations | Large Laboratory 33ft x 22ft | Small Laboratory 22ft x 11ft |
|------------------------------|---|---|
| Short Wall | 56,56b,88,91,94,106 | 115,154,155 |
| Under bulkhead | 54,54b,86,89,92 | 98,98c,103,103c,139-141,139c-141c,190-192 |
| Two - Same Wall | | 156-167 |
| Two - Opposite Walls | | 167-175 |
| Two - Perpendicular | | 176-178 |
| Person in Front of Hood: | | |
| No | 0-30, 35-42,41b,47-81,86-94,106-107,122-125, 142-145 | 82-85,95-105,108-121,126-141,179-193 |
| Yes 4" | 43,45,49c,50c,69c-75c,146-147 | 82c-85c,95c-105c,108c-113c,116c-121c,126c-141c,148-178 |
| Yes 6" | 44,46 | |
| In front | 31,32 | |
| In front with equipment | 33,34 | |
| Heat Source : | | |
| None | 0,35-40 | 0,35-40 |
| 5.16/5.3 W/sq ft | 28-30,122-125 | 126-129 |
| 7.75 W/sq ft | 1,2,4-11,13-15,18,19,31-34 | |
| 8.0 W/sq ft | 3,12,16,17,20-27,41-56,41b,49c,50c, 54b-56b, 58-81,61b, 63b,69c-75c,86-94,106-107,142-147 | 82-85,82c-85c,95-105,95c-105c,108-121,108c-113c,116c-121c,138-141, 139c-141c,148-193 |
| 10.3/10.4 W/sq ft | | 130-137 |
| 12 W/sq ft | 57 | |
| Make-up Air Position : | | |
| None | 18-21 | |
| Under Door 1 ¹ | 1-17, 22-34,41-75,41b,49c,50c,54b-56b,61b,63b,69c-75c,86-94,122-125, 142-147 | 82-85, 84b,82c-85c ,95-05,99b,95105c,108 ³ ,108c ³ ,126-141,126c-137c,139c-141c.148-193 |
| Under All Doors ¹ | 76 | |

| Simulations | Large Laboratory 33ft x 22ft | Small Laboratory 22ft x 11ft |
|-------------------------------------|---|--|
| Transfer Grille Door 1 ¹ | 77,79-81,107 ³ | 82-85,84b,82c-85c,95-105, 99b,95c-105c,108 ³ ,108c ³ ,109-121,109c-113c, 116c-117c, 126-141,126c-137c, 139c-141c,148-183 |
| Transfer Grille Door 2 ¹ | 78,106 | |
| All - Hood in Isolation | 0,35-40 | 0,35-40 |
| Make-up Air Quantity ⁴ : | | |
| None | 18-21 | |
| 56 cfm | 122-125 | |
| 100 cfm | 1-17,22-34,41-78,41b,49c,50c,54b-56b,61b,63b,69c-75c,80,81, 86-94,106,107,118-121 | 118-121,118c-121c,184-192 |
| 166 cfm | | 157,160,161,164,165,167-178,193 |
| 200 cfm | 79 | |
| 300 cfm | | 130-133,130c-133c |
| 381 cfm | | 109,109c,110,110c |
| 419 cfm | | 82-85,82c-85c,95-105,95c-105c,108, 108c,111-117,111c-113c,116c-117c, 134-141,134c-137c,139c-141c,148-155,179-183 |
| 467 cfm | | 156,158,159,162,163,166 |
| 513 cfm | 142-147 | |
| 542 cfm | | 126-129,126c-129c |
| All | 0,35-40 | 0,35-40 |

Notes for Table 3.07

1. Make-up Air Locations

Door 1 is the main door into the laboratory through one of the short walls. Doors 2 and 3 are 'corridor' doors at the opposite end of the laboratory but on the long walls. For a door, when leakage is allowed it is defined as coming through a crack under the appropriate door. Where transfer grilles have been included they measure 12" x 24" and are placed above the stated door with a 50% free area ratio and a loss coefficient of 1.5.

2. Down-flow from whole ceiling

Simulations of down - flow from the whole ceiling were intended to provide a good environment for the hood. However, it was found that the very low velocity resulting from the distributed momentum source allowed the heat sources to dominate the flow and the desired effect was not achieved. This approach was therefore abandoned.

3. Main door moved

These simulations are with the main door moved closer or farther away relative to the hood wall. This means that the make - up air position moves relative to the door.

3.4 Grid Selection

Although CFD is a well tested and established technique, there is a further level of testing required to ensure that the simulations are predicting performance as accurately as possible. This testing is often termed 'grid selection' or 'grid sensitivity studies'. The testing is so termed because the grid needs to be sufficiently refined to minimize numerical error. The number of grid cells significantly affects the calculation time for each simulation, and so it is necessary to identify the minimum number of grid cells that allow prediction of the solution with sufficient accuracy. This is particularly critical around the sash opening where variations in velocity, turbulence, and concentration are very high. The grid selected has to be sufficient to capture these high gradients, if not, then, in particular, excessive numerical diffusion of the concentration may occur.


Two levels of grid dependency tests are performed. The first checks that the general flows and temperature predictions within the laboratory do not change when the number of grid cells is changed, and the second investigates the contaminant diffusion from the face of the hood.

The general flow is assessed using one of the large laboratory simulations (run072 - table 3.08), with the results from two different calculation grids being compared.


Table 3.08 Comparison of grid in run072.

| | Number of grid cells in each direction | | | Total number of grid cells |
|---------------------------------|--|----|----|----------------------------|
| | x | y | z | |
| Fine grid - whole lab | 54 | 56 | 39 | 117 936 |
| Fine grid - box region | 14 | 9 | 12 | 1 512 |
| Coarse grid - whole lab | 45 | 43 | 33 | 63 855 |
| Coarse grid - box region | 8 | 4 | 7 | 224 |

The results show no significant deviation from one simulation to another. Figure 3.32 shows the flow and temperature distribution, in a section at a height of 4 ft 4 in (1.3 m) above the floor for the two calculations for a qualitative comparison. The flow in the critical area around the hood is assessed further in a quantitative manner. An imaginary box is drawn around the sash opening to a distance of 12" in front of the hood. The air flow and temperature through each face is recorded (tables 3.09 and 3.10) and is found to closely match. The sides of the box are referred to by their position relative to the hood along a particular axis. For example the low x side is to the side of the hood closer to the origin ($x = 0.0$) and high x the side further from the origin. Hence, with a fine grid, and to the side of the hood closer to the origin 0.0727 kg/s of air flows towards the hood. This is at a temperature of 21.66°C. This compares to a flow rate of 0.0742 kg/s at a temperature of 21.63°C obtained using a coarse grid, which is an acceptable error.



Coarse Grid



Refined Grid




Figure 3.32 Visual comparison of resv/l's from grid sensitivity.

Table 3.09 Air flow comparison.

| Case | Air flow through imaginary box (kg/s) | | | | |
|--------|---------------------------------------|---------|--------|--------|---------|
| | low x | high x | low y | low z | high z |
| Fine | 0.0727 ⁽¹⁾ | -0.0575 | 0.1766 | 0.0552 | -0.0878 |
| Coarse | 0.0742 | -0.0604 | 0.1689 | 0.0551 | -0.0847 |

¹ Sign indicates direction of flow relative to axis direction

Table 3.10 Temperature comparison.

| Case | Temperature of air passing through sides of box (°C) | | | | |
|--------|--|--------|-------|----------------|--------|
| | low x | high x | low y | low z | high z |
| Fine | 21.66 | 21.66 | 22.10 | 21.23 21.57 | 23.14 |
| Coarse | 21.63 | 21.69 | 22.07 | 21.19 21.55 | 23.12 |

The second part of the grid dependency testing focuses on the diffusion of the tracer from the sash opening. Three grids are tested (table 3.11). Use is made of a grid distribution facility that enables non uniform grid spacing across selected regions, refining the cell distribution towards the edges of the opening. In this way, small calculation cells are present at the edges where the high gradients of velocity, turbulence, and concentration can be expected. This can be done most easily by specifying a power law distribution that stipulates that the cell sizes increase and decrease according to the factor (power) and the type. There are three types :

If the cell size gets bigger as the coordinate increases, this is denoted an increasing type.

If the cell size gets smaller as the coordinate decreases, this is denoted a decreasing type.

If the cells get bigger and then get smaller again, this is denoted symmetric type.

The sash opening is considered to be full of concentration (kg species / kg air).


The grid is specified in regions. These regions are set relative to a distance from the origin of the coordinate system for the model. In this model the x axis ran across the hood face and the y axis was perpendicular to the hood face. The hood face was set at a position $y = 2.24$ m from the origin of the model.

Table 3.11 Comparison of grids


| File name | Grid across face (x axis) | | |
|--------------------------|-------------------------------|-------------------------------|-------------------------------|
| | Side (low x) | Across face | Side (high x) |
| Coarse grid | 2 cells uniform spacing | 8 cells, symmetric factor 1.4 | 2 cell uniform spacing |
| Intermediate grid | 3 cells decreasing factor 1.5 | 8 cells, symmetric factor 1.4 | 3 cells increasing factor 1.5 |
| Fine grid | 4 cells uniform | 8 cells, symmetric factor 1.4 | 4 cells uniform |

| File name | Grid perpendicular to face (y axis) | | | |
|--------------------------|-------------------------------------|-------------------------------|--------------------------------|-------------------------------|
| | from $y = 0.0$ to $y = 1.24$ | from $y = 1.24$ to $y = 1.91$ | from $y = 1.24$ to $y = 2.11$ | from $y = 2.11$ to $y = 2.24$ |
| Coarse grid | 6 cells uniform spacing | 5 cells uniform spacing | 2 cells uniform spacing | 1 cell uniform spacing |
| Intermediate grid | 6 cells uniform spacing | 5 cells uniform spacing | 2 cells uniform spacing | 2 cells decreasing factor 2.0 |
| Fine grid | 6 cells uniform spacing | 8 cells uniform spacing | 4 cells decreasing factor 1.45 | 4 cells uniform spacing |

Figure 3.33 shows the concentration plotted along two lines. The first is a line parallel to the sash opening, 7 in (0.18 m) from the opening, and 12 in. (0.30 m) above the working surface. The second, again 12 in above the surface, is perpendicular to the sash opening near the center. Comparison of the results shows a considerable difference between the coarse and fine grids. However, the results with the intermediate grid (and the one that is used in the main simulations) compared well with the fine grid.



Across face.



Perpendicular to face.

Figure 3.33 Comparison of concentration around hood with different grids.

3.5 Assumptions

Several modeling assumptions are taken throughout the project. While many laboratory configurations are considered, these modeling assumptions are necessary to focus the scope of this research.

A solar load is not modeled through the windows and walls.

Floor, ceiling, and walls are assumed to have no heat transfer; that is the surrounding areas are assumed to be at the same temperature.

Shelving is specified as thin plates, ignoring any effect of thickness but still providing a barrier to airflow and surface friction on the horizontal surfaces. In a typical laboratory these shelves contain books, equipment, and supplies. In order to make the representation as generic as possible individual items are not modeled. Rather the effect of these items are represented by a defining a resistance to air flow creating a pressure drop and thus restricting the flow into and along the shelves. Other equipment is modeled as solid obstructions placed around the laboratory on the work benches. All surfaces are considered to be smooth when calculating surface friction.

All cases with double hoods have a person 4" away from the faces of the hood and all lighting and duct work recessed in the ceiling cavity.

The person modeled has a prescribed heat gain of 75 W distributed non - uniformly over the body. No account of body motion is taken.

In large labs, with the ductwork exposed, a general laboratory exhaust is mounted just below the ceiling level and exiting the laboratory through a short wall.

Lighting throughout the labs is 2.3 W/ft^2 in the form of fluorescent tubes suspended from, or recessed into, the ceiling. A split of approximately 50/50 is assumed in the convective / radiative components of the lighting heat gain.

The hood is modeled without any special aerodynamic (airfoil) design around the entry. The geometry of the hood is formed from a number of rectangular objects representing the base and the walls, with wedge shaped objects for sloping surfaces. The sash itself is represented as a thin plate preventing flow through it. The sash is assumed to be at its maximum opening position (30 in, 0.76 m) for the majority of simulations. Some simulations are conducted with the sash open at 25%.

The total flow - rate through the hood is set so that the average face velocity was 100 fpm (0.507 m/s). Several simulations are conducted with an average face velocity of 50 fpm (0.254 m/s).

At 100 fpm (0.507 m/s) the total flow rate through the hood is 784 cfm (0.44 kg/s). Table 3.12 describes the details of flow through different hood slots. This assumed that the hood is correctly installed and balanced.

Table 3.12 Hood slot flow rates

| Slot Location | Width of slot | | Flow - rate through slot | |
|---------------|---------------|--------|--------------------------|-------|
| | inches | meters | cfm | kg/s |
| Bottom Slot | 2.5 | 0.064 | 470 | 0.264 |
| Middle Slot | 1.5 | 0.038 | 157 | 0.088 |
| Top Slot | 0.5 | 0.013 | 157 | 0.088 |
| Total | | | 784 | 0.440 |

Just inside, the hood sash opening is filled with the contamination to represent the worst case scenario of leakage. The tracer gas has the same density as the ambient air.

The laboratory temperature is kept at 72°F (22.2°C) throughout all simulations except 0 - 40 inclusive, where the laboratory temperature is 71°F (21.6°C).

No leakage occurs in to or out of the laboratory other than that specified through crack(s) under the door or a transfer grille.

The crack under the door provides 100 cfm (0.06 kg/s) to maintain -0.008" of water pressure (-2 Pascal) in the lab.

Supply diffusers are formed from a number of boundary conditions so that the jet velocity and direction are specified.

Supply diffusers are selected from manufacturers data to provide the required flow rates whilst keeping within the noise criteria of between 35 and 40 dB.

Equipment is represented as either a heat input over a volume, or, a solid object with heat output over the surface. The former simply puts heat into the air, while the latter represents blockage effects.

Density variations due to temperature are negligible. Density is therefore ignored in all terms apart from the buoyancy source term in the momentum equation. This is known as the Boussinesq approximation.

In practice, the contaminant is so diluted that variation of the mixture density due to differing molecular weights is negligible.